AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		2

2. AMENDMENT/MODIFICAITON NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicble)
AMENDMENT NO. 0003	08/24/17		17-0023

6. ISSUED BY	CODE	7. ADMINISTERED BY (If other than Item 6)	CODE
ROICC Camp Lejeune 1005 Michael Road Camp Lejeune, NC 28547-2521	ROICCF1	See Item 6	

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICIATION NO.
	x	N40085-17-R-3114
		9B. DATED (SEE ITEM 11) 08/08/17
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[x] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended, [x] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a)By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPIRATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [x] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Project 17-0023 Interior and Exterior Repairs, BEQ HP513

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal.

~CONTINUED~

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Incorporate the following into solicitation N4008517R3114:

1. Sheet M-101, Mechanical Building New Work Plan1, Mechanical Building Northwest Side 3, and Boiler Section 4: Change HHWS and HHWR pipe size from 3 inch to 4 inch.

2. Sheet M-101, Mechanical Building New Work Plan1, and Boiler Section 4: Change HHWS/HHWR/Boiler piping to be primary/secondary loop piping arrangement to match detail 1 on sheet M504.

3. Sheet M-101, Mechanical Building New Work Plan1, and Boiler Section 4: Show boiler pipe size as 2 inch.

4. Sheet MS-101, Site Mechanical Piping New Work Plan: Change HHWS and HHWR pipe size from junction of common pipe (205 gpm) to individual building service (103 gpm), from 4" to 3". Continue the 3" pipe size into building through to second floor.

5. Sheet M-601, Airflow Measurement Device Schedule: Change CFM for AFMD-1C/2C/3C to read 160/250/330 CFM.

6. Sheet M-601, Sidewall Louver Schedule: Change minimum free area of SWL-1/2/3 to 0.8 sf.

7. All other terms and conditions remain unchanged.